

Option C7 For Temperature Transmitters

SPECIAL CONSIDERATIONS FOR TRANSMITTERS ORDERED WITH THE C7 OPTION

IMPORTANT


Transmitters ordered with the C7 option are factory configured for a special sensor type/range.

When using a HART Communicator or other digital interface, do not disable the special sensor from the “Sensor Config” menu and do not select *non standard* from the “Select Sensory Type” menu.

If the special sensor is disabled or *non standard* is selected, the special configuration will be erased from the transmitter memory and the it will need to be returned to the factory so the special sensors type/range can be reset.

Transmitters configured for the C7 option are shipped with the security on, ensuring that the special configuration is protected. If tag, descriptor, or message field changes are desired, the transmitter security must first be turned off. The security jumper is located on the front of the electronics module and is labelled “SECURITY.” After changes are made, return the jumper to the “ON” position.

Table 1-1. Transmitter Switch Location



*Rosemount and the Rosemount logotype are registered trademarks of Rosemount Inc.
All other marks are the property of their respective owners.*

Emerson Process Management

Rosemount Inc.
8200 Market Boulevard
Chanhassen, MN 55317 USA
T (U.S.) 1-800-999-9307
T (International) (952) 906-8888
F (952) 949-7001

www.rosemount.com



**Emerson Process Management
Temperature GmbH**
Frankenstrasse 21
63791 Karlstein
Germany
T 49 (6188) 992 0
F 49 (6188) 992 112

**Emerson Process Management Asia
Pacific Private Limited**
1 Pandan Crescent
Singapore 128461
T (65) 6777 8211
F (65) 6777 0947
AP.RMT-Specialist@emersonprocess.com



EMERSON™
Process Management