



- ③ THE PARABOLIC ANTENNA MUST BE HORIZONTAL WITHIN $\pm 0.5^\circ$. INCLINATION DEVICE CAN BE USED IF TANK FLANGE IS WITHIN 3' (REFERENCE HORIZONTAL).
- ② ITEM 03 IS TO BE WELDED OR SCREWED ON TANK FLANGE. SEE DRAWING: MECHANICAL INSTALLATION WELDING OF T38-W 9240003-944 OR SCREWED T30 9240003-947.
- ① RECOMMENED INSTALLATION DISTANCE FROM TANK WALL TO RADAR GAUGE IS 600mm, INSTALLATION CLOSER TO TANK WALL MAY REDUCE PERFORMANCE.

POS	ITEM DESCRIPTION	QTY	REMARK	SUPPLIER
05	GASKET	1	ACC TO FLANGE STD	CUSTOMER
04	BOLTING	1	ACC TO FLANGE STD	CUSTOMER
03	FLANGE BALL	1	SEE NOTE 2.	RTR
02	TANK FLANGE/COVER	1	SEE NOTE 2 AND 3.	CUSTOMER
01	TANK SOCKET	1		

ISSUED BY				INSTALLATION DRAWING TITLE				
GU-HF	WEEK 0307	PRODUCT CODE PRO/5600	FILE ACAD	MECHANICAL INSTALLATION DWG PRO/5600, PARABOLIC ANTENNA				
APPROVED BY GST-TK		WEEK 0307	ORIGINAL DWG NO. 9240003-948	SCALE -	DOC TYPE 2			DWG NO. 9240003-948
ROSEMOUNT				1 ST ANGLE			ISSUE 4	SHEET 1/1

THE COPYRIGHT/OWNERSHIP OF THIS DOCUMENT IS AND WILL REMAIN OURS. THE DOCUMENT MUST NOT BE USED WITHOUT OUR AUTHORIZATION OR BROUGHT TO THE KNOWLEDGE OF A THIRD PARTY. CONTRAVENTION WILL BE PROSECUTED. ROSEMOUNT TANK RADAR AB, SWEDEN.

FOR MORE INFO. SEE INSTALLATION MANUAL.
SEE SPECIAL INSTALLATION DWG FOR "POWDER" APPLICATIONS i.e. CEMENT SILOS.