



1/2-14 NPT CONDUIT/CABLE
 THREAD (BOTH SIDES).
 M20x1.5, PG13.5
 ADAPTERS (OPTIONAL)

1 P/T-RATING FOR FLANGE; SEE REF. MANUAL.

DEPENDENT ON TURBULENCE
 IN TANK AND MOUNTING ANGLE
 THE PROBE MAY NEED TO BE
 ANCHORED OR SUPPORTED.

04	GASKET	1	ACC. TO BSP-G THREAD STD.	CUSTOMER
03	GASKET	1	SOFT GASKET T=MIN 1.6 (ANSI B16.5/1a, EN1514-1/1BC). SPIRAL WOUND GASKET WITH NON METALLIC FILLER (ANSI B16.5/1b, EN1514-2). SEE NOTE 1.	CUSTOMER
02	SCREW/NUT/WASHER	-	ACC. TO FLANGE STD, SEE NOTE 1.	CUSTOMER
01	FLANGE	1	DIM. ACC. TO ANSI B 16.5/EN 1092-1. OTHER ON REQUEST. P/T RATING, SEE NOTE 1.	RMT
PDS ITEM DESCRIPTION QTY REMARK				SUPPLIER

ISSUED BY	WEEK	PRODUCT CODE	FILE	INSTALLATION DRAWING TITLE	
GU-TK-MA	0707	5300	PRO/E	MECHANICAL INSTALLATION DWG COAXIAL LEAD HTHP	
APPROVED BY	WEEK	ORIGINAL DWG NO.	SCALE	ISSUE	SHEET
GU-HF	0707		1:5	01	1/1



DOC TYPE	DWG NO.	ISSUE	SHEET
2	9240017-996	01	1/1

THE COPYRIGHT/OWNERSHIP OF THIS DOCUMENT IS AND WILL REMAIN OURS. THE DOCUMENT MUST NOT BE USED WITHOUT OUR AUTHORIZATION OR BROUGHT TO THE KNOWLEDGE OF A THIRD PARTY. CONTRAVENTION WILL BE PROSECUTED. ROSEMOUNT TANK RADAR AB, SWEDEN.

FOR MORE INFO. SEE
 REFERENCE MANUAL.