



DEPEND ON TURBULENCE IN TANK AND MOUNTING ANGEL THE PROBE MAY NEED TO BE ANCHORED OR SUPPORTED.

FOR MORE INFO, SEE REFERENCE MANUAL.

1. P/T-RATING FOR FLANGE; SEE REF. MANUAL.

| | | | | |
|-----|------------------|-----|--|----------|
| 04 | GASKET | I | ACC. TO BSP-G THREAD STD. | CUSTOMER |
| 03 | GASKET | I | SOFT GASKET T-MIN 1,6 (ANSI B16.5/16, EN1514-1/1BC), SPIRAL WOUND GASKET WITH NON METALLIC FILLER (ANSI B16.5/16, EN1514-2), SEE NOTE 1. | CUSTOMER |
| 02 | SCREW/NUT/WASHER | - | ACC. TO FLANGE STD. SEE NOTE 1. | CUSTOMER |
| 01 | FLANGE | I | DIM. ACC. TO ANSI B 16.5/EN 1092-1, OTHER ON REQUEST. P/T RATING, SEE NOTE 1. | RMT |
| POS | ITEM DESCRIPTION | QTY | REMARK | SUPPLIER |

| | | | | |
|-------------------|------|-------------------|-------|-----------------------------|
| ISSUED BY | MEK | PRODUCT CODE | FILE | INSTALLATION DRAWING TITLE |
| Eme-HW-C | 0909 | 3300 | PRO/E | MECHANICAL INSTALLATION DWG |
| APPROVED BY | MEK | ORIGINAL DWG. NO. | SCALE | COAXIAL LEAD HTHP |
| Eme-HF | 0909 | 9240017-999 | - | |
| ROSEMOUNT® | | | | DWG NO. |
| T-SI ANGLE | | | | 2 |
| DOC TYPE | | | | DWG NO. |
| | | | | 9240017-999 |
| | | | | ISSUE |
| | | | | 03 |
| | | | | SHEET |
| | | | | 1/1 |

THE COPYRIGHT/OWNERSHIP OF THIS DOCUMENT IS AND WILL REMAIN OURS. THE DOCUMENT MUST NOT BE USED WITHOUT OUR AUTHORIZATION OR BROUGHT TO THE KNOWLEDGE OF A THIRD PARTY. CONTRAVENTION WILL BE PROSECUTED. ROSEMOUNT TANK-RADAR AB, SWEDEN