



RECOMMENDED D>100 [4]  
 MIN D=50 [2] REQUIRES  
 SPECIAL CONFIG SETTINGS.  
 MAX REC. H<(D+100) [D+4]

DEPENDENT ON TURBULENCE IN TANK  
 AND MOUNTING ANGLE THE PROBE MAY  
 NEED TO BE ANCHORED OR SUPPORTED.  
 ENSURE MID PROBE HAS NO CONTACT  
 WITH WALL.

1. P/T-RATING FOR FLANGE, SEE REF MANUAL.

04	GASKET	1	ACC. TO BSP-G THREAD STD.	CUSTOMER
03	GASKET	1	SOFT GASKET T=MIN 1.6 (ANSI B16.5/1a, EN1514-1/1BC). SEE NOTE 1.	CUSTOMER
02	SCREW/NUT/WASHER	-	ACC. TO FLANGE STD, SEE NOTE 1.	CUSTOMER
01	FLANGE	1	DIM. ACC. TO ANSI B 16.5/EN 1092-1. OTHER ON REQUEST. P/T RATING, SEE NOTE 1.	RMT
PDS	ITEM DESCRIPTION	QTY	REMARK	SUPPLIER

ISSUED BY	WEEK	PRODUCT CODE	FILE	INSTALLATION DRAWING TITLE
GU-TK-TR	0640	5300	PRO/E	MECHANICAL INSTALLATION DWG RIGID TWIN LEAD
APPROVED BY	WEEK	ORIGINAL DWG NO.	SCALE	
GU-HF	0640			

<b>ROSEMOUNT</b>	1 ST ANGLE	DWG TYPE	DWG NO.	ISSUE	SHEET
		2	9240030-995	01	1/1

THE COPYRIGHT/OWNERSHIP OF THIS DOCUMENT IS AND WILL REMAIN OURS. THE DOCUMENT MUST NOT BE USED WITHOUT OUR AUTHORIZATION OR BROUGHT TO THE KNOWLEDGE OF A THIRD PARTY. CONTRAVENTION WILL BE PROSECUTED. ROSEMOUNT TANK RADAR AB, SWEDEN.

FOR MORE INFO SEE  
 REFERENCE MANUAL