

EC Declaration of Conformity

No: RMD 1062 Rev. C

We,

**Mobrey Ltd.
158 Edinburgh Avenue
Slough, SL1 4UE
GB**

declare under our sole responsibility that the product,

Rosemount 3100 Series Ultrasonic Level Transmitter

manufactured by,


**Mobrey Ltd.
158 Edinburgh Avenue
Slough, SL1 4UE
GB**

to which this declaration relates, is in conformity with the provisions of the European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community notified body certification, as shown in the attached schedule.

11th December 2009.

(date of issue)



(signature)

David J. Ross-Hamilton

(name - printed)

Global Approvals Consultant

(function name - printed)

Schedule
No: RMD 1062 Rev. C

EMC Directive (2004/108/EC)

Model 3101LA*FNA**, 3102HA*F**NA****, 3105HA*F**I1****, 3107HP*P**I1****, 3108HP*P**I1******

EN 61326-1:2006, EN 61326-2.3:2006

ATEX Directive (94/9/EC)**Model 3105HA*F**I1******

Sira 06ATEX2260X – Intrinsically Safe
Equipment Group II, Category 1 G (Ex ia IIC T4/T6 Ga)
EN 60079-0:2006, EN 60079-11:2007, EN 60079-26:2004

Model 3107HP*PI1****, 3108HP*P**I1******

Sira 09ATEX2299X – Intrinsically Safe
Equipment Group II, Category 1 G (Ex ia IIC T4/T6 Ga)
EN 60079-0:2006, EN 60079-11:2007, EN 60079-26:2007
The following Technical Standards and Specifications have been applied:
IEC 60079-0:2007

(Minor variations in design to suit the application and/or mounting requirements are identified by alpha/numeric characters where indicated * above)

Schedule
No: RMD 1062 Rev. C

ATEX Notified Body for EC Type Examination Certificate

SIRA Certification Service [Notified Body Number: 0518]
Rake Lane, Eccleston, Chester
Cheshire, CH4 9JN, GB

ATEX Notified Body for Quality Assurance

SIRA Certification Service [Notified Body Number: 0518]
Rake Lane, Eccleston, Chester
Cheshire, CH4 9JN, GB

