

ROSEMOUNT



EC Declaration of Conformity

No: RMD 1063 Rev. B

We,

Mobrey Ltd.
158 Edinburgh Avenue
Slough, SL1 4UE
GB

declare under our sole responsibility that the product,

Rosemount 3490 Universal Control Unit

manufactured by,

Mobrey Ltd.
158 Edinburgh Avenue
Slough, SL1 4UE
GB

to which this declaration relates, is in conformity with the provisions of the European Community Directives, including the latest amendments, as shown in the attached schedule.

Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community notified body certification, as shown in the attached schedule.

17 AUGUST 2010

(date of issue)

(signature)

David J. Ross-Hamilton

(name - printed)

Global Approvals Consultant

(function name - printed)

Schedule
No: RMD 1063 Rev. B

EMC Directive (2004/108/EC)

Model 3491L***, 3492L*****, 3493L*******
EN 61326-1:2006; Class A (Industrial Radiated Emission Limits)

LVD Directive (2006/95/EC)

Model 3491L1***, 3492L1*****, 3493L1*******
EN61010-1:2000

ATEX Directive (94/9/EC)

Model 349*L*P4I1 , 349*L*P6I1****
Sira 06ATEX7128 – Intrinsically Safe & Dust Certificate
Equipment Group II, Category (1) GD ([Ex ia Ga] IIC [Ex iaD Da] IIIC)
EN 60079-0:2006, EN 60079-11:2007, EN 60079-26:2004, EN 61241-11:2006
The following Technical Standards and Specifications have been applied:
IEC 60079-0:2007

Model 349*L*P7I1**
Sira 06ATEX7129X – Intrinsically Safe & Dust Certificate
Equipment Group II, Category (1) GD ([Ex ia Ga] IIC [Ex iaD Da] IIIC)
EN 60079-0:2006, EN 60079-11:2007, EN 60079-26:2004, EN 61241-11:2006
The following Technical Standards and Specifications have been applied:
IEC 60079-0:2007

(Minor variations in design to suit the application and/or mounting requirements are identified by alpha/numeric characters where indicated * above)



Schedule
No: RMD 1063 Rev. B

ATEX Notified Body for EC Type Examination Certificates

SIRA Certification Service [Notified Body Number: 0518]
Rake Lane, Eccleston, Chester
Cheshire, CH4 9JN, GB

ATEX Notified Body for Quality Assurance

SIRA Certification Service [Notified Body Number: 0518]
Rake Lane, Eccleston, Chester
Cheshire, CH4 9JN, GB

