

# EC Declaration of Conformity

No: RMD 1071 Rev. A

---

We,

**Rosemount Inc.**  
**8200 Market Boulevard**  
**Chanhassen, MN 55317-6985**

*declare under our sole responsibility that the product,*

## **Models 2051 Pressure Transmitter**

*manufactured by,*

**Rosemount Inc.**  
**12001 Technology Drive**  
**Eden Prairie, MN 55344-3695**  
**USA**

*and*

**8200 Market Boulevard**  
**Chanhassen, MN 55317-9687**  
**USA**

*to which this declaration relates, is in conformity with the provisions of the European Community Directives, including the latest amendments, as shown in the attached schedule.*

*Assumption of conformity is based on the application of the harmonized standards and, when applicable or required, a European Community notified body certification, as shown in the attached schedule.*



---

(signature)

---

**Timothy J Layer**

(name - printed)

---

**Vice President of Global Quality**

(function name - printed)

---

**15-Aug-2008**

(date of issue)

## EC Declaration of Conformity

No: RMD 1071 Rev. A

---

### EMC Directive (2004/108/EC)

**All Models 2051 Pressure Transmitters**  
EN 61326:2006

---

### PED Directive (97/23/EC)

**Models 2051CG2, 3, 4, 5; 2051CD2, 3, 4, 5 (also with P9 option); Pressure Transmitters**  
QS Certificate of Assessment - EC No. PED-H-100  
Module H Conformity Assessment

**All other model 2051 Pressure Transmitters**  
Sound Engineering Practice

**Transmitter Attachments: Diaphragm Seal - Process Flange - Manifold**  
Sound Engineering Practice

---

### ATEX Directive (94/9/EC)

#### Model 2051 Pressure Transmitter

Certificate: BAS08ATEX0129X  
Intrinsically Safe - Group II Category 1 G  
Ex ia IIC T4 (Ta = -60°C to +70°C)  
Ex ia IIC T4 (Ta = -60°C to +60°C) FISCO

Harmonized Standards Used:  
EN60079-0:2006; EN60079-11:2007

Certificate: Baseefa08ATEX0130X  
Type n - Group II Category 3 G  
Ex nA nL IIC T4 (Ta = -40°C to +70°C)

Harmonized Standards Used:  
EN60079-0:2006; EN60079-15:2005

Certificate: KEMA08ATEX0090X  
Flameproof - Group II Category 1/2 GD  
Ex d IIC T6 (-50°C ≤ Ta ≤ +65°C)  
Ex d IIC T5 (-50°C ≤ Ta ≤ +80°C)

Harmonized Standards Used:  
EN60079-0:2006; EN60079-1:2007; EN60079-26:2007

Certificate: Baseefa08ATEX0182X  
Type Dust - Group II Category 1 D  
Ex tD A20 T115°C (-20°C ≤ Ta ≤ +85°C)

Harmonized Standards Used:  
EN61241-0:2006; EN61241-1:2004

## EC Declaration of Conformity

No: RMD 1071 Rev. A

---

### PED Notified Body

**Det Norske Veritas (DNV)** [Notified Body Number: 0575]  
Veritasveien 1, N-1322  
Hovik, Norway

---

### ATEX Notified Bodies for EC Type Examination Certificate

**KEMA (KEMA)** [Notified Body Number: 0344]  
Utrechtseweg 310, 6812 AR Arnhem  
P.O. Box 5185, 6802 ED Arnhem  
The Netherlands  
Postbank 6794687

**Baseefa.** [Notified Body Number: 1180]  
Rockhead Business Park  
Staden Lane  
Buxton, Derbyshire  
SK17 9RZ United Kingdom

---

### ATEX Notified Body for Quality Assurance

**Baseefa.** [Notified Body Number: 1180]  
Rockhead Business Park  
Staden Lane  
Buxton, Derbyshire  
SK17 9RZ United Kingdom