



Certificate of Compliance

Certificate Number: LR 87488-2
KEMA Ref. 97.3255

Revision: LR 87488-5

Date Issued: September 10, 1997

Issued To: El-o-matic B.V.
P.O. Box 155,
5430 AD Cuijck,
The Netherlands

The products listed below are eligible to bear the CSA Mark.

Issued By: J. Pankowski
CSA Montreal

Signature

PRODUCTS

Valve actuators, 110V, 60Hz, 1-ph, max. ambient temperature 25C, Types:

	Rating	Duty cycle (sec)			Rating	Duty cycle (sec)	
		ON	OFF			ON	OFF
<u>EL20</u>	0.8A	6	15	<u>EL200</u>	2.1A	12	48
<u>EL35</u>	1.1A	5	15	<u>EL350</u>	2.1A	19	76
<u>EL70</u>	2.1A	6	20	<u>EL500</u>	2.1A	25	65
<u>EL100</u>	2.1A	6	24	<u>EL800</u>	2.7A	22	70
<u>EL150</u>	2.1A	7,5	40				

APPLICABLE REQUIREMENTS

- CAN/CSA-C22.2 No. 0 - M91 - General Requirements
- CAN/CSA-C22.2 No.77 - 1988 - Motors with Inherent Overheating Protection
- CAN/CSA-C22.2 No.94 - 1976 - Special Purpose Enclosures 2, 3, 4 and 5
- CAN/CSA-C22.2 No.139 - 1982 - Electrically Operated Valves

Electrical Certification Notice No.: 277D, 277E