

# Certificate of Compliance

**Certificate:** 1796497

**Master Contract:** 174756

**Project:** 1796497

**Date Issued:** May 29, 2006

**Issued to:** Emerson Process Management Valve Automation Div.,  
EI-O-Matic B.V.  
Asveldweg 11  
7556BR Hengelo  
THE NETHERLANDS

*The products listed below are eligible to bear the CSA Mark shown  
with adjacent indicators 'C' and 'US'*

**Issued by:** O. Ewanchyna, P. Eng.



**Authorized by:** M.H.J. Hoendervangers



## PRODUCTS

CLASS 2252 05 - PROCESS CONTROL EQUIPMENT

CLASS 2252 85 - PROCESS CONTROL EQUIPMENT-Certified to US Standards

Valve Actuator Controller FieldQ, Model QC02, permanently connected, rated 85-254 V, 50/60 Hz, 2,85 W

## APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 61010.1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

UL Std. No. 61010-1 (2<sup>nd</sup> Edition) - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use - Part 1: General Requirements

## CONDITIONS OF ACCEPTABILITY

The unit is evaluated for an ambient temperature of 80 °C

The membrane keyboard is only accessible by means of a tool. Only trained personal may control the unit.

The unit may only be used in combination with a pneumatic module mounted on an actuator to prevent against electric shock.

The 'C' and 'US' indicators adjacent to the CSA Mark signify that the product has been evaluated to the applicable CSA and ANSI/UL Standards, for use in Canada and the U.S., respectively. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards 179649 May 29, 2001 74751796497



CSA INTERNATIONAL

## *Supplement to Certificate of Compliance*

**Certificate:** 1796497

**Master Contract:** 174756

*The products listed, including the latest revision described below,  
are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
1796497	May 29, 2006	cCSAus Original Certification Valve Actuator Controller FieldQ, Model QC02