

SWITCHES, MISCELLANEOUS, FOR HAZARDOUS LOCATIONS CERTIFICATE



CERTIFICATE No. Ex 030496-100737
30 August 1996

Issued to: Hytork Controls Ltd.
Eastern Avenue
Gloucester
GL4 3BZ England
United Kingdom

This is to certify that the Safevision Explosion-Proof Valve Position Indicator for use in Class I, Groups C and D; Class II, Groups E, F and G; Class I, Division 2, Groups A and B Hazardous Locations have been investigated by Underwriters Laboratories Inc. in accordance with the Standard for Hazardous (Classified) Locations indicated in this certificate.

UL Standards for Safety:

UL 1203, Explosion-Proof and Dust-Ignition-Proof Electrical Equipment for Use in Hazardous (Classified) Locations

The devices comply with the requirements as defined by the Standard indicated in this document for Hazardous Locations.

To establish that the product is under the Certification program, it is necessary to determine that the Listing Mark is affixed to the product. Only those products bearing the appropriate Listing Mark and the company's name, trade name, trademark, or other recognized identification should be considered as covered by UL's Listing and Follow-Up Service. The Listing Mark for the devices includes the symbol of Underwriters Laboratories Inc., "®", together with the word "Listed", the control number, and the product name.

Code: Switches, Miscellaneous, (WTEV) Hazardous Locations

Temperature Code: T6

T amb = -25 C to 40 C

Investigation and Test
Report Reference:
E181737, 1 July 1996

Paul T. Kelly
Associate Managing Engineer
Engineering Services -418B