High Process Noise Field Guide

WHY USE HIGH PROCESS NOISE DIAGNOSTIC?

The Rosemount High Process Noise diagnostic detects if there is a process condition causing unstable or noisy readings, but the noise is not real flow variation. One common cause of high process noise is slurry flow, like pulp stock or mining slurries. Other conditions that cause this diagnostic to activate are high levels of chemical reaction or entrained gas in the liquid. If unusual noise or variation is seen, this diagnostic will activate and deliver a PlantWebTM alert. If this situation exists and is left without remedy, it will add additional uncertainty and noise to the flow reading. For more information on functionality and theory of operation, see page 2.

HOW TO SET-UP

 Confirm that the High Process Noise diagnostic is available (option code DA1/D01) and enabled. For more information on ordering this option, see page 3.

Field Comm. Fast Keys	1, 2, 1, 1, Empty Pipe
LOI Menu	Diagnostics, Diag Controls,
	Process Noise
AMS	Context Menu, Diagnostics and
	Tests
Enhanced DD	Configure, Manual Setup,
	Diagnostics, Enable Diagnostics

- 2. Confirm that flow rate is greater than 1 ft/s. This diagnostic requires that flow be present in pipe.
- 3. Read value of Coil Drive Frequency.

Field Comm. Fast Keys	1, 2, 2, 4
LOI Menu	Diagnostics, Basic Diag, Empty
	Pipe
AMS Tab	Diagnostics
Enhanced DD	Configure, Manual Setup,
	Diagnostics, Empty Pipe

4. Read value of 5 Hz SNR (Signal-to-Noise Ratio) and 37 Hz SNR. Signal-to-Noise Ratio (SNR) is a measure of the signal strength relative to the amount of process noise present. The coil drive can operate at two frequencies (5 Hz and 37 Hz), and the SNR is monitored at both frequencies. If the transmitter is operating in 5 Hz mode, and the 5 Hz SNR remains below 25 for one minute, then the High Process Noise diagnostic alert will activate. Similarly, if the transmitter is operating in 37 Hz SNR remains below 25 for one minute, then the High Process Noise diagnostic alert will activate. Similarly, if the transmitter is operating in 37 Hz mode, and the 37 Hz SNR remains below 25 for one minute, then the High Process Noise diagnostic alert will activate. For more information on the SNR parameters, see page 3.

Field Comm. Fast Keys	5 Hz: 1, 2, 4, 4
	37 Hz: 1, 2, 4, 5
LOI Menu	Diagnostics, Variables, 5Hz SNR
	or 37Hz SNR
AMS Tab	Context Menu, Diagnostics and
	Tests
Enhanced DD	Configure, Manual Setup,
	Diagnostics, High Process Noise
	Detection

5. If the transmitter detects high levels of process noise, see page 4 for troubleshooting procedures.





HIGH PROCESS NOISE

The High Process Noise diagnostic detects if there is a process condition causing unstable or noisy readings, but the noise is not real flow variation. One common cause of high process noise is slurry flow, like pulp stock or mining slurries. Other conditions that cause this diagnostic to activate are high levels of chemical reaction or entrained gas in the liquid. If unusual noise or variation is seen, this diagnostic will activate and deliver a PlantWeb alert. If this situation exists and is left without remedy, it will add additional uncertainty and noise to the flow reading.

High Process Noise Functionality

The High Process Noise diagnostic is useful for detecting situations where the process fluid may be causing electrical noise resulting in a poor measurement from the magnetic flow meter. There are three basic types of process noise that can affect the performance of the magnetic flowmeter system.

1/f Noise

This type of noise has higher amplitudes at lower frequencies, but generally degrades over increasing frequencies. Potential sources of 1/f noise include chemical mixing and the general background noise of the plant.



Spike Noise

This type of noise generally results in a high amplitude signal at specific frequencies which can vary depending on the source of the noise. Common sources of spike noise include chemical injections directly upstream of the flowmeter, hydraulic pumps, and slurry flows with low concentrations of particles in the stream. The particles bounce off of the electrode generating a "spike" in the electrode signal. An example of this type of flow stream would be a recycle flow in a paper mill.



White Noise

This type of noise results in a high amplitude signal that is relatively constant over the frequency range. Common sources of white noise include chemical reactions or mixing that occurs as the fluid passes through the flowmeter and high concentration slurry flows where the particulates are constantly passing over the electrode head. An example of this type of flow stream would be a basis weight stream in a paper mill.



The transmitter continuously monitors signal amplitudes over a wide range of frequencies. For the high process noise diagnostic, the transmitter specifically looks at the signal amplitude at frequencies of 2.5 Hz, 7.5 Hz, 32.5 Hz, and 42.5 Hz. The transmitter uses the values from 2.5 and 7.5 Hz and calculates an average noise level. This average is compared to the amplitude of the signal at 5 Hz. If the signal amplitude is not 25 times greater than the noise level, and the coil drive frequency is set at 5 Hz, the High Process Noise diagnostic will activate indicating that the flow signal may be compromised. The transmitter performs the same analysis around the 37.5 Hz coil drive frequency using the 32.5 Hz and 42.5 Hz values to establish a noise level.



ENABLING THE HIGH PROCESS NOISE DIAGNOSTIC

The High Process Noise diagnostic can be turned on or off using AMS Suite: Intelligent Device Manager, a Field Communicator, or the Local Operator Interface (LOI) as required by the application. If the Advanced Diagnostics Suite 1 (DA1/D01 option) was ordered, then the High Process Noise diagnostic will be turned on. If DA1/D01 was not ordered or licensed, this diagnostic is not available. However, the DA1/D01 option is available for purchase after the meter is installed. Contact your local sales representative to trial or order this option in the field.

UNDERSTANDING THE HIGH PROCESS NOISE PARAMETERS

The High Process Noise diagnostic has two read-only parameters. It does not have any configurable parameters. This diagnostic requires that flow be present in the pipe.

5 Hz Signal to Noise Ratio

This is the current value of the signal to noise ratio at the coil drive frequency of 5 Hz. This is a read-only value. This number is a measure of the signal strength at 5 Hz relative to the amount of process noise present. If the transmitter is operating in 5 Hz mode, and the signal to noise ratio at 5 Hz remains below 25 for one minute, then the High Process Noise diagnostic alert will activate.

37 Hz Signal to Noise Ratio

This is the current value of the signal to noise ratio at the coil drive frequency of 37 Hz. This is a read-only value. This number is a measure of the signal strength at 37 Hz relative to the amount of process noise present. If the transmitter is operating in 37 Hz mode, and the signal to noise ratio at 37 Hz remains below 25 for one minute, then the High Process Noise diagnostic alert will activate.

TROUBLESHOOTING THE HIGH PROCESS NOISE DIAGNOSTIC

The following procedures can be used in the event that the transmitter detects high levels of process noise.

If the High Process Noise diagnostic activates while operating in 5 Hz mode, proceed with the following steps:

- Increase transmitter coil drive frequency to 37 Hz and, if possible, perform an Auto Zero (for details on changing the coil drive frequency or performing an Auto Zero, consult the installation manual).
- 2. Verify sensor is electrically connected to the process with grounding electrode, grounding rings with grounding straps, or lining protector with grounding straps.
- 3. If possible, redirect chemical additions downstream of the magmeter.
- 4. Verify process fluid conductivity is above 10 microsiemens/cm.

If the signal to noise ratio is less than 25 while operating in 37 Hz mode, proceed with the following steps:

- 1. Turn on the Digital Signal Processing (DSP) function and follow the setup procedure (refer to the installation manual for more details). This will minimize the level of damping in the flow measurement and control loop while also stabilizing the reading to minimize valve actuation.
- 2. Increase damping to stabilize the signal (refer to the installation manual for details). This will add dead-time to the control loop.

The Emerson logo is a trade mark and service mark of Emerson Electric Co. Rosemount and the Rosemount logotype are registered trademarks of Rosemount Inc. All other marks are the property of their respective owners.

Standard Terms and Conditions of Sale can be found at www.rosemount.com/terms_of_sale

Emerson Process Management
Rosemount Flow
7070 Winchester Circle
Boulder, Colorado USA 80301
Tel (USA) 1 800 522 6277
Tel (International) +1 303 527 5200
Fax +1 303 530 8549

Emerson Process Management Blegistrasse 23 P.O. Box 1046 CH 6341 Baar Switzerland Tel +41 (0) 41 768 6111 Fax +41 (0) 41 768 6300

Emerson FZE P.O. Box 17033 Jebel Ali Free Zone Dubai UAE Tel +971 4 811 8100 Fax +971 4 886 5465 Emerson Process Management Asia Pacific Pte Ltd 1 Pandan Crescent Singapore 128461 Tel +65 6777 8211 Fax +65 6777 0947 Service Support Hotline : +65 6770 8711 Email : Enquiries@AP.EmersonProcess.com



NOTE

Activating the DSP or increasing the damping may stabilize the flow signal, but will not clear the High Process Noise diagnostic message. To clear the diagnostic message, the High Process Noise diagnostic will need to be disabled.

3. Move to a Rosemount High-Signal flowmeter system. This system will deliver a stable signal by increasing the amplitude of the flow signal by up to ten times to increase the signal to noise ratio. For example if the signal to noise ratio (SNR) of a standard magmeter is 5, the High-Signal would have a SNR of 50 in the same application. The Rosemount High-Signal system is comprised of the 8707 sensor which has modified coils and magnetics and the 8712H High-Signal transmitter.

NOTE

In applications where very high levels of noise are a concern, it is recommended that a dual-calibrated Rosemount High-Signal 8707 sensor be used. These sensors can be calibrated to run at lower coil drive current supplied by the standard Rosemount transmitters, but can also be upgraded by changing to the 8712H High-Signal transmitter.